

William D. Roney

N.E.A.V.F.D.

Pleasant Grove, Route 9 - Burlington, North Carolina 27215

C. N. E. Williams Fire Capt

August 3, 1990

RECEIVED
N.C. Dept. NRCD

AUG 6 1990

Winston-Salem
Regional Office

NC Dept. of Natural Resources & Community Development
8025 North Point Boulevard
Suite 100.
Winston-Salem, NC 27106-3295

Dear Sirs:

Enclosed is the site information on the tank removal at our facility.

- I. One underground storage tank (550 gallons) was used to store gasoline.
- II. The soil samples were taken by hand auger, at depths of one foot below depth of the tank.
- III. The samples were taken by Jerry Beckom, Alamance County Hazardous Material Planner, and hand delivered by Mr. Beckom to Burlington Research.
- IV. The tanks were removed by one of the volunteer firemen and transferred to his farm.
- V. The residue of product was pumped from the tank and disposed of by Four Seasons of Greensboro.

If you have any questions regarding this information, please contact Jerry Beckom at the Alamance County Fire Marshal's Office at 228-1312.

Yours truly,


James A. Roney, Jr.
James A. Roney, Jr.
Fire Chief

JAR:jr

Enclosure

PROJECT SITE INFORMATION
NORTHEASTERN VOL. FIRE DEPT.
HWY. 49 NORTH OF HAW RIVER, NC.
JULY 13, 1990

NORTH



Excavated pit where a 550 gal.
UST was located. Pit was about
5 ft. deep.

Highway 49



Analytical Services • Aquatic Bioassay Testing • Aquatic Toxicity Reduction Evaluations
AATCC Testing Services • NPDES Testing • Reporting & Data Handling Services
PMN Aquatic Bioassay Evaluations

AUG 3 1990

Post Office Box 2481 • 615 Huffman Mill Road • (919) 584-5564 • Burlington, NC 27215

August 01, 1990

Fire Marshall's Office,
Alamance County
124 Elm Street
Graham, NC 27253

Attention: Mr. Jerry Beckam

Enclosed, find report(s) for your sample(s) received
07/13/90, BRI Work Order # 90-07-089. Please call if you
have any questions.

Thank you.

Sincerely

A handwritten signature in cursive script, appearing to read 'Steve Yocklovich'.

Steve Yocklovich
Director, Chromatography Laboratories



Analytical Services • Aquatic Bioassay Testing • Aquatic Toxicity Reduction Evaluations
AATCC Testing Services • NPDES Testing • Reporting & Data Handling Services
PMN Aquatic Bioassay Evaluations

Post Office Box 2481 • 615 Huffman Mill Road • (919) 584-5564 • Burlington, NC 27215

ANALYTICAL REPORT

CUSTOMER: ALAMANCE COUNTY
FACILITY: Graham, NC
SAMPLE: Special Study
Sample #1
WORK ORDER #: 90-07-089-01
SAMPLE REC'D: 07/13/90
REPORT DATE: 08/01/90
REPORT TO: Mr. Jerry Beckam

PARAMETER	UNITS	RESULTS
TPH-I, Soil	mg/Kg (ppm)	ATTACHED



Analytical Services • Aquatic Bioassay Testing • Aquatic Toxicity Reduction Evaluations
AATCC Testing Services • NPDES Testing • Reporting & Data Handling Services
PMN Aquatic Bioassay Evaluations

Post Office Box 2481 • 615 Huffman Mill Road • (919) 584-5564 • Burlington, NC 27215

EPA METHOD 5030 WITH CALIFORNIA GC METHOD
TOTAL PETROLEUM HYDROCARBONS - TYPE I, IN SOILS

WORK ORDER #: 90-07-089-01

TPH: <10 mg/kg (ppm)

TPH Standard used: Leaded Gasoline



Analytical Services • Aquatic Bioassay Testing • Aquatic Toxicity Reduction Evaluations
AATCC Testing Services • NPDES Testing • Reporting & Data Handling Services
PMN Aquatic Bioassay Evaluations

Post Office Box 2481 • 615 Huffman Mill Road • (919) 584-5564 • Burlington, NC 27215

ANALYTICAL REPORT

CUSTOMER: ALAMANCE COUNTY
FACILITY: Graham, NC
SAMPLE: Special Study
Sample #2
WORK ORDER #: 90-07-089-02
SAMPLE REC'D: 07/13/90
REPORT DATE: 08/01/90
REPORT TO: Mr. Jerry Beckam

PARAMETER	UNITS	RESULTS
TPH-I, Soil	mg/Kg (ppm)	ATTACHED



Analytical Services • Aquatic Bioassay Testing • Aquatic Toxicity Reduction Evaluations
AATCC Testing Services • NPDES Testing • Reporting & Data Handling Services
PMN Aquatic Bioassay Evaluations

Post Office Box 2481 • 615 Huffman Mill Road • (919) 584-5564 • Burlington, NC 27215

EPA METHOD 5030 WITH CALIFORNIA GC METHOD
TOTAL PETROLEUM HYDROCARBONS - TYPE I, IN SOILS

WORK ORDER #: 90-07-089-02

TPH: <10 mg/kg (ppm)

TPH Standard used: Leaded Gasoline